



CERTIFICATE OF ANALYSIS

Batch No: 24-25218
Final Report 172157

Page 1 of 2

Client: Veolia Environmental Services
Contact: [REDACTED]
Address: Locked Bag 6000
SOUTH MELBOURNE
VIC
3205
AUSTRALIA

*Laboratory
Address*

Scoresby Laboratory
Caribbean Business Park,
22 Dalmore Drive,
Scoresby,
VIC 3179
03 8756 8000
03 9763 1862

*Phone
Fax
Contact:*

[REDACTED]
[REDACTED]

PO No: 7300346657

Date Sampled: 09-Apr-2024

Sampler Name:

Date Samples Received: 10-Apr-2024

ALS Program Ref: VEOLIA_CFA

Date Issued: 19-Apr-2024

Program Description: CFA VEMTC
Client Ref: CFA Penshurst APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Temp (Field)	EN67.2	Scoresby	BOD5	WP030	Scoresby
E.coli, Coliforms	MM698	Scoresby	Enterolert	MM517	Scoresby
Legionella	MM527	Scoresby	SS at 104+/- 2°C	WA025	Scoresby

Signatories

Name	Title	Name	Title
[REDACTED]	Client Manager	[REDACTED]	Analyst
[REDACTED]	Analyst	[REDACTED]	Analyst
[REDACTED]	Analyst		

Samples not collected by ALS and are tested as received.
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.
The report shall not be reproduced, except in full and results relate only to the items tested.

Batch No: 24-25218
 Report Number: 172157
 Client: Veolia Environmental Services
 ALS Program Ref: VEOLIA_CFA
 Program Description: CFA VEMTC



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
9737998	WTP1-APWS	Alternative Potable Water Supply	WATER	09/04/24 09:00

Analysis - Analyte	Sample No.	9737998
	Site Code	WTP1-APWS
	Units	
Temp (Field) - Temperature (Field)	°C	17.3
pH (Field) - pH (Field)	Units	6.6
Field Cl2 - Free Chlorine (Field)	mg/L	1.0
Field Cl2 - Total Chlorine (Field)	mg/L	1.2
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10

A blank space indicates no test performed.