



# CERTIFICATE OF ANALYSIS

**Batch No:** 24-30453  
*Final Report* 183626

Page 1 of 2

**Client:** Veolia Environmental Services  
**Contact:** [REDACTED]  
**Address:** Locked Bag 6000  
SOUTH MELBOURNE  
VIC  
3205  
AUSTRALIA

**Laboratory Address:** Wangaratta Laboratory  
48 Faithfull Street,  
Wangaratta,  
VIC 3677.  
**Phone:** 03 5722 2688  
**Fax:** 03 5722 4727

**Contact:** [REDACTED]

**PO No:** 7300346657

**Date Sampled:** 07-May-2024

**Sampler Name:** [REDACTED]  
**ALS Program Ref:** VEOLIA\_CFA

**Date Samples Received:** 07-May-2024

**Date Issued:** 15-May-2024

**Program Description:** CFA VEMTC  
**Client Ref:** CFA Wangaratta APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Wangaratta	pH (Field)	EN67.2	Wangaratta
Temp (Field)	EN67.2	Wangaratta	BOD5	WP030	Wangaratta
E.coli, Coliforms	MM698	Wangaratta	Enterolert	MM517	Wangaratta
Legionella	MM527	Wangaratta	SS at 104+/- 2°C	WA025	Wangaratta

### Signatories

Name	Title	Name	Title
[REDACTED]	Client Manager	[REDACTED]	Analyst
	Laboratory Co-ordinator		
	Wangaratta		

Samples not collected by ALS and are tested as received.  
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila  
Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.  
The report shall not be reproduced, except in full and results relate only to the items tested.

Batch No: 24-30453  
 Report Number: 183626  
 Client: Veolia Environmental Services  
 ALS Program Ref: VEOLIA\_CFA  
 Program Description: CFA VEMTC



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
9825915	WTP2-APWS	Alternative Potable Water Supply	WATER	07/05/24 08:45

Analysis - Analyte	Sample No.	9825915
	Site Code	WTP2-APWS
	Units	
Temp (Field) - Temperature (Field)	°C	16.1
pH (Field) - pH (Field)	Units	7.4
Field Cl2 - Free Chlorine (Field)	mg/L	2.3
Field Cl2 - Total Chlorine (Field)	mg/L	2.6
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	6
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10

A blank space indicates no test performed.