



# CERTIFICATE OF ANALYSIS

**Batch No:** 24-37207  
*Final Report* 192054

Page 1 of 2

*Client:* **Veolia Environmental Services**  
*Contact:* [REDACTED]  
*Address:* Locked Bag 6000  
SOUTH MELBOURNE  
VIC  
3205  
AUSTRALIA

*Laboratory  
Address*

**Scoresby Laboratory**  
Caribbean Business Park,  
22 Dalmore Drive,  
Scoresby,  
VIC 3179  
03 8756 8000  
03 9763 1862

*Phone  
Fax  
Contact:*

[REDACTED]  
[REDACTED]

*PO No:* 7300346657

*Date Sampled:* 11-Jun-2024

*Sampler Name:* [REDACTED]  
*ALS Program Ref:* VEOLIA\_CFA

*Date Samples Received:* 11-Jun-2024

*Date Issued:* 21-Jun-2024

*Program Description:* CFA VEMTC  
*Client Ref:* CFA West Sale APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Temp (Field)	EN67.2	Scoresby	BOD5	WP030	Scoresby
Colilert (2000)	MM514	Scoresby	Enterolert	MM517	Scoresby
Legionella	MM527	Scoresby	SS at 104+/- 2°C	WA025	Scoresby

## Signatories

Name	Title	Name	Title
[REDACTED]	Client Manager	[REDACTED]	Team Leader Nutrients
[REDACTED]	Analyst	[REDACTED]	Analyst
[REDACTED]	Analyst	[REDACTED]	

Samples not collected by ALS and are tested as received.  
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila  
Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.  
The report shall not be reproduced, except in full and results relate only to the items tested.

Batch No: 24-37207  
 Report Number: 192054  
 Client: Veolia Environmental Services  
 ALS Program Ref: VEOLIA\_CFA  
 Program Description: CFA VEMTC



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
9942234	WTP4-APWS	Alternative Potable Water Supply	WATER	11/06/24 10:20

Analysis - Analyte	Sample No.	9942234
	Site Code	WTP4-APWS
	Units	
Temp (Field) - Temperature (Field)	°C	11.6
pH (Field) - pH (Field)	Units	7.1
Field Cl2 - Free Chlorine (Field)	mg/L	0.88
Field Cl2 - Total Chlorine (Field)	mg/L	0.96
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	2
Colilert (2000) - Coliform	MPN/100mL	0
Colilert (2000) - E.coli	MPN/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10

A blank space indicates no test performed.