



CERTIFICATE OF ANALYSIS

Batch No: **24-42462**
Final Report **197454**

Page 1 of 2

Client: **Veolia Environmental Services**
Contact: [REDACTED]
Address: Locked Bag 6000
SOUTH MELBOURNE
VIC
3205
AUSTRALIA

Laboratory
Address

Scoresby Laboratory
Caribbean Business Park,
22 Dalmore Drive,
Scoresby,
VIC 3179
03 8756 8000
03 9763 1862

Phone
Fax
Contact:

[REDACTED]
[REDACTED]

PO No: **7300346657**

Date Sampled: **04-Jul-2024**

Sampler Name: [REDACTED]
ALS Program Ref: **VEOLIA_CFA**

Date Samples Received: **04-Jul-2024**

Date Issued: **12-Jul-2024**

Program Description: **CFA VEMTC**
Client Ref: **CFA Penshurst APWS**

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Cl2	EN67.2	Scoresby	pH (Field)	EN67.2	Scoresby
Temp (Field)	EN67.2	Scoresby	BOD5	WP030	Scoresby
E.coli, Coliforms	MM698	Scoresby	Enterolert	MM517	Scoresby
Legionella	MM527	Scoresby	SS at 104+/- 2°C	WA025	Scoresby

Signatories

Name	Title	Name	Title
[REDACTED]	Client Manager	[REDACTED]	Team Leader Nutrients
[REDACTED]	Analyst	[REDACTED]	Analyst
[REDACTED]	Analyst		

Samples not collected by ALS and are tested as received.
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.
The report shall not be reproduced, except in full and results relate only to the items tested.

Batch No: 24-42462
 Report Number: 197454
 Client: Veolia Environmental Services
 ALS Program Ref: VEOLIA_CFA
 Program Description: CFA VEMTC



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
10032263	WTP1-APWS	Alternative Potable Water Supply	WATER	04/07/24 09:00

Analysis - Analyte	Sample No.	10032263
	Site Code	WTP1-APWS
	Units	
Temp (Field) - Temperature (Field)	°C	13.2
pH (Field) - pH (Field)	Units	6.6
Field Cl2 - Free Chlorine (Field)	mg/L	0.92
Field Cl2 - Total Chlorine (Field)	mg/L	1.0
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10

A blank space indicates no test performed.