



CERTIFICATE OF ANALYSIS

Batch No: 24-48473
Final Report 203930

Page 1 of 2

Client: Veolia Environmental Services
Contact: [REDACTED]
Address: Locked Bag 6000
SOUTH MELBOURNE
VIC
3205
AUSTRALIA

Laboratory Address: Geelong Laboratory,
16 Crown Street,
South Geelong,
VIC 3220
Phone: 03 5246 9400
Fax:

Contact: [REDACTED]
[REDACTED]

PO No: 7300346657

Date Sampled: 01-Aug-2024

Sampler Name: [REDACTED]
ALS Program Ref: VEOLIA_CFA

Date Samples Received: 02-Aug-2024

Date Issued: 09-Aug-2024

Program Description: CFA VEMTC
Client Ref: CFA Penshurst APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Chlorine	# CLIENT	Geelong	pH	# CLIENT	Geelong
Temp.	# CLIENT	Geelong	Colilert (2000)	MM514	Geelong
Enterolert	MM517	Geelong	BOD5	WP030	Geelong
Legionella	MM527	Geelong	SS at 104+/- 2°C	WA025	Geelong

Signatories

Name	Title	Name	Title
[REDACTED]	Client Manager	[REDACTED]	Chemistry Coordinator
[REDACTED]	Analyst	[REDACTED]	Microbiologist

Samples not collected by ALS and are tested as received.
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.
The report shall not be reproduced, except in full.

Batch No: 24-48473
 Report Number: 203930
 Client: Veolia Environmental Services
 ALS Program Ref: VEOLIA_CFA
 Program Description: CFA VEMTC



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
10131474	WTP1-APWS	Alternative Potable Water Supply	WATER	01/08/24 11:30

Analysis - Analyte	Sample No. Site Code Units	10131474 WTP1-APWS
Temp. - Water Temperature (CS)	C	10.90
pH - pH (CS)	Units	7.41
Field Chlorine - Free Chlorine (CS)	mg/L	0.82
Field Chlorine - Total Chlorine (CS)	mg/L	1.00
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2 C - Suspended Solids	mg/L	<2
Colilert (2000) - Coliform	MPN/100mL	0
Colilert (2000) - E.coli	MPN/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10

A blank space indicates no test performed.