



# CERTIFICATE OF ANALYSIS

Batch No: 24-52852  
Final Report 210775

Page 1 of 2

Client: Veolia Environmental Services  
Contact: [REDACTED]  
Address: Locked Bag 6000  
SOUTH MELBOURNE  
VIC  
3205  
AUSTRALIA

Laboratory  
Address

Wangaratta Laboratory  
48 Faithfull Street,  
Wangaratta,  
VIC 3677.

Phone  
Fax

03 5722 2688  
03 5722 4727

Contact:

Carmin De Palma  
Client Manager  
Carmin.DePalma@alsglobal.com

PO No: 7300346657

Date Sampled: 26-Aug-2024

Sampler Name: [REDACTED]  
ALS Program Ref: VEOLIA\_CFA

Date Samples Received: 26-Aug-2024

Date Issued: 04-Sep-2024

Program Description: CFA VEMTC  
Client Ref: CFA Wangaratta APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Chlorine	# CLIENT	Wangaratta	pH	# CLIENT	Scoresby
Temp.	# CLIENT	Scoresby	BOD5	WP030	Wangaratta
E.coli, Coliforms	MM698	Wangaratta	Enterolert	MM517	Wangaratta
Legionella	MM527	Wangaratta	SS at 104+/- 2°C	WA025	Wangaratta

## Signatories

Name	Title	Name	Title
Carmin De Palma	Client Manager	Jodie Evans	Analyst
Kate Byvoet-Mullins	Laboratory Co-ordinator Wangaratta		

Samples not collected by ALS and are tested as received.  
Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila  
Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.  
The report shall not be reproduced, except in full.

Batch No: 24-52852  
 Report Number: 210775  
 Client: Veolia Environmental Services  
 ALS Program Ref: VEOLIA\_CFA  
 Program Description: CFA VEMTC



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
10207381	WTP2-APWS	Alternative Potable Water Supply	WATER	26/08/24 12:36

Analysis - Analyte	Sample No.	10207381
	Site Code	WTP2-APWS
	Units	
Temp. - Water Temperature (CS)	C	11.90
pH - pH (CS)	Units	6.66
Field Chlorine - Free Chlorine (CS)	mg/L	2.23
Field Chlorine - Total Chlorine (CS)	mg/L	2.30
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2 C - Suspended Solids	mg/L	4
E.coli, Coliforms - Coliforms	cfu/100mL	0
E.coli, Coliforms - E.coli	cfu/100mL	0
Enterolert - Enterococci	MPN/100mL	0
Legionella - Total Legionellae	cfu/mL	<10
Legionella - Legionella pneumophila	cfu/mL	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	<10

A blank space indicates no test performed.